

Government of Bihar
Public Health Engineering Department
Monthly Water Quality Monitoring Report
Division Name: P.H.Division, Ara

District Name: Bhojpur (Ara)
Sample Collected By: Self School Staff

Date Of Sampling: 05/06/21
Date Of Testing: 07/06/21

Sl. No.	Block	Panchyat	Village	Habitation	Location of Source	Parameters																Remarks
						pH	Turb	EC	TDS	TH	Ca	Mg	Cl	Alka	Fu	NO ₃	SO ₄	F	As	Total Coll		
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	
1	Ara	Ara Town	Singhi	Ward No01	Rajkeshwar Singh Chunmun Devi Saraswati Vidya Mandir	7.27	1	390	255	140	NT	NT	25	160	0.15	NT	NT	0.10	BDL	NT	Safe	
Permissible Limit* in absence of alternative source						6.5-8.5	1	-	500	200	75	30	250	200	1	45	200	1	0.01	-	-	
*NT= Not Tested , BDL=Below Detection Limit						NR	5	-	2000	600	200	100	1500	600	NR	NR	400	1.5	NR	-	-	

Qaf
07.06.21
Pub Asst

रविंद्र कुमार चौधरी
07/06/21
रसायनवा

Handwritten signature and stamp in green ink.